

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1080878

Product: Lightning and surge arrester

Type: V 25-B+C

Rating: 230 V AC, 100 kA

Ordering firm: OBO Bettermann Praha s. r. o.
Modletice 81, 251 01 Říčany u Prahy, Czech Republic

Manufacturer: OBO Bettermann GmbH + Co.KG
Hüingsler Ring 52, Menden D-58694, Germany

Factories: OBO Bettermann GmbH + Co.KG
Hüingsler Ring 52, Menden D-58694, Germany

Trade mark:


The test results are stated in the test-report No.: 802466-01/01 of: 12.08.2008

A sample of the product was found to be in conformity with:
ČSN EN 61643-11:03+A11:07

The validity of the certificate is limited to: 30.9.2011

5.9.2008

Prague


Pavel Kudrna
Certification and Inspection Manager



Stamp



802466-01

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1080877

Product: Lightning and surge arrester with signalisation

Type: V 25-B+C/FS, AS

Rating: AC 230 V, 100 kA

Ordering firm: OBO Bettermann Praha s. r. o.
Modletice 81, 251 01 Říčany u Prahy, Czech Republic

Manufacturer: OBO Bettermann GmbH + Co.KG
Hüingser Ring 52, Menden D-58694, Germany

Factories: OBO Bettermann GmbH + Co.KG
Hüingser Ring 52, Menden D-58694, Germany

Trade mark:


The test results are stated in the test-report No.: 802465-01/01 of: 12.08.2008

A sample of the product was found to be in conformity with:
ČSN EN 61643-11:03+A11:07

The validity of the certificate is limited to: 30.9.2011

5.9.2008

Prague


Pavel Kudrna
Certification and Inspection Manager



Stamp



802465-01

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1080876

Product: Lightning and surge arrester

Type: V 20-C

Rating: 230 V AC, 15 kA

Ordering firm: OBO Bettermann Praha s. r. o.
Modletice 81, 251 01 Říčany u Prahy, Czech Republic

Manufacturer: OBO Bettermann GmbH + Co.KG
Hüingsler Ring 52, Menden D-58694, Germany

Factories: OBO Bettermann GmbH + Co.KG
Hüingsler Ring 52, Menden D-58694, Germany

Trade mark:


The test results are stated in the test-report No.: 802464-01/01 of: 11.08.2008

A sample of the product was found to be in conformity with:
ČSN EN 61643-11:03+A11:07

The validity of the certificate is limited to: 30.9.2011

5.9.2008

Prague


Pavel Kudrna
Certification and Inspection Manager



Stamp



802464-01

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1080875

Product: Voltage discharge gap

Type: V 25-B+C/...+NPE, V 20-C/...+NPE

Rating: 255 V AC, 50/60 Hz, 40 kA

Ordering firm: OBO Bettermann Praha s. r. o.
Modletice 81, 251 01 Říčany u Prahy, Czech Republic

Manufacturer: OBO Bettermann GmbH + Co.KG
Hüingser Ring 52, Menden D-58694, Germany

Factories: OBO Bettermann GmbH + Co.KG
Hüingser Ring 52, Menden D-58694, Germany

Trade mark:


The test results are stated in the test-report No.: 802463-01/01 of: 11.08.2008

A sample of the product was found to be in conformity with:
ČSN EN 61643-11:03+A11:07

The validity of the certificate is limited to: 30.9.2011

5.9.2008

Prague


Pavel Kudrna
Certification and Inspection Manager



Stamp



802463-01